

# COCHIN FIRE GUARD

ISO 9001:2015 SERVICE CENTRE

50/931, Near Gov. Dispensary, Devankulangara, Edappally-24  
Ph : 0484-2348849 / 2335554 Mob: 9447036859,  
Email : weguardfirecontrol@yahoo.com

## FIRE PROTECTION ENGINEERS



### TEST CERTIFICATE


M/s. NATIONAL PUBLIC SCHOOL  
Deshabhimeni Road, Karukapally  
Kaloor - 682 017

Sl No.	Type	Capacity	Fire Classification	Qty	Body Shall Internal	Hydraulic Pressure Test	Inspection Date	Next Due Date
1	DCP	21kg	BC	02	OK	NIL	11/09/23	10/09/24
2	ABC SP	11kg	ABC	01	OK	NIL	11/09/23	10/09/24
3	ABC SP	21kg	ABC	01	OK	NIL	11/09/23	10/09/24
4	ABC SP	41kg	ABC	03	OK	NIL	11/09/23	10/09/24
5	ABC SP	51kg	ABC	03	OK	NIL	11/09/23	10/09/24
6	CO2	45kg	BC	02	OK	NIL	11/09/23	10/09/24

Cochin  
Date :

11/09/2023



  
Signature With Seal  
of Technician